



**MAYOR AND CITY COUNCIL OF LAUREL  
DEPARTMENT OF THE FIRE MARSHAL AND PERMIT SERVICES**

8103 Sandy Spring Road • Laurel, Maryland 20707 (301) 725-5300 extension 2238

<https://www.cityoflaurel.org> • email – [fmps@laurel.md.us](mailto:fmps@laurel.md.us)

**Mobile and Temporary Food Service Permit**

THIS PERMIT SHALL BE POSTED DURING TIMES OF OPERATION

Company Name: \_\_\_\_\_ Tag #, State: \_\_\_\_\_

Make/ Model of Vehicle: \_\_\_\_\_

Pass	Fail	Checklist for Inspector
		Two valid 10-pound ABC extinguishers on hand. (Substitute one class K if cooking with grease, Workers must be trained to use extinguisher if needed.
		Proper wheel chocks are present and adequate. Must be able to stop vehicle from rolling if brakes fail.
		Carbon Monoxide Detector, must be securely installed inside the vehicle.
		Hood extinguishing system must have been inspected by a certified company, within the last six months. Exhaust system free from excessive grease. Pull station mounted near exit / unobstructed.
		Cooking operations are no less than 25 feet from the building (s).
		Portable generator / Fueled / Exhaust separation (Spare gasoline is kept in approved containers.
		Propane & natural gas / leak test by operator / Maryland certified gas fitter signed statement.
		Electric Wiring / Cords / Conduit / Boxes / Fixtures, all multiplug adapters are UL listed power strips.
		Health Department Approval
Remarks For Items Not Checked Off Above:		
( ) – License Approved      ( ) – License Disapproved      ( ) – Reinspection		
Date	Owner / Occupant Print Name	Owner / Occupant Signature
Date	Inspector Print Name	Inspector Signature